

UNIT SMOKE ALARMS.**EFFECTIVE JUNE 15TH. 2006.**

In accordance with the Bylaws of Condominium Corporation No. 0513297 the Board of Directors has passed the following rule:

TO ALL CONDOMINIUM RESIDENTS.

Please take note that your suite is equipped with a unit Smoke Alarm(s) for your protection. The Smoke Alarm(s) were in good working order prior to you occupying your unit and as per the yearly Fire Alarm Inspection.

To ensure your own safety, it is very important to maintain your Smoke Alarm as follows:

1. Press the test button once a week to check the internal buzzer or horn.
2. Once a month, test the Smoke Alarm with smoke by lighting a candle and then blowing it out. Let the smoke from extinguished candle waft into Smoke Alarm. To turn the alarm off simply wave or fan the detector with a newspaper to clear the smoke from the chamber.
3. Once per year, use a vacuum cleaner to vacuum the accumulated dust out of the Smoke Alarm.
4. Some Smoke Alarms are equipped with a battery backup feature and require the 9-volt battery to be changed once a year when there is a delayed single beeping sound.
5. If you should find that the Smoke Alarm does not work, have it replaced immediately. E-mail condo.varsity@gmail.com the Board of Directors or 3111bldg.mngr@gmail.com the building manager to have the Smoke Alarm replaced.